



Demand Side Management Working Group

and it was suggested that the IMO determine the maximum demand for eight consecutive intervals during each month. The level of Certification of a Curtailable Load would be equal to the median metered consumption of the load during the highest eight consecutive Trading Intervals over the preceding twelve month period.

A fair measure needs to be developed for loads that do not have interval metered consumption for twelve months.