Surface water source



b

f g

d c

Groundwater source

i

g f g f f l

e d k

,

This note does not focus on private water supplies for individual households, such as farmhouses, although it may assist in awareness of issues and help with water supply decision-making. For advice on private water supply systems, see our Water quality protection note (WQPN) 41 Private water supplies (reference 6b). For waters used for agricultural water supplies such as crop irrigation or stock water, see our WQPN 45 Rural land use and water quality.

Advice and recommendations

Commitment to providing a safe drinking water supply

1 Those developing or operating drinking water sources should be aware of the risks of contamination to the sources, and provide effective protective measures to ensure the safety of water consumers.

The Australian drinking water guidelines (ADWG) (reference 1d) define an effective framework for developing and

communities on pastoral leases, Crown land or reserves. A Community layout (development) plan recorded with planning authorities is recommended where formal local or regional planning schemes don't apply. A development referral and assessment framework should be implemented by the catchment manager to influence any land use change that may affect the water source.

16 Subdivision proponents should be guided by the Western Australian Planning Commission bulletin 45 Subdivision referrals to service providers (reference 12) prior to submitting an application to subdivide.

17 Where local government acts as a planning regulator of land developments which cater for residential communities or tourist accommodation, a project approval condition should include: 'Provision of a safe drinking water supply that meets the Australian Drinking Water guidelines 2004 recommendations and is managed by a trained operator approved by the Economic Regulation Authority or the Department of Health (WA).

Implementation schedule

18 An implementation schedule which identifies the timing and who is responsible for each action—recommended in the drinking water source protection plan—should be prepared. This should be incorporated into local land planning controls. Water system operators should have appropriate training, equipment and resources to effectively implement the plan.

Define the area requiring protection

19 The catchment area or groundwater area for the community drinking water source should be defined by mapping. Methods used and justification for selection should be documented. Surface water catchments and shallow, sand or gravel aquifers are considered most vulnerable to contamination. Deep aquifers fully confined by clay, shale or low-permeability rock and protected from contamination via well designed bores (reference 10) may require a smaller protection area.

20 A map of the proposed protection area should be prepared. These areas are most effectively protected when owned by the water service operator, leased or subject to a written legal agreement covering protection measures, unless the community agrees to cooperate to achieve the common goal of source protection. This protected area should generally include all water sources, any groundwater recharge zone and catchment portion that produces run-off into any surface water source.

Catchment protection measures

Water source vulnerability to on-site contamination

21 All on-site activities that could release contaminants into the environment, such as sewage disposal systems, fuel storage, chemical residue from crops or gardens, wastes from animals, compost heaps, workshop residues and waste landfills should be listed, and measures to control contaminant losses installed and maintained.

22 Any potentially contaminating activities (where fluids can move through soils) should all be located down the hydraulic gradient from drinking water sources.

23 The types of local soils, drainage paths and hydro-geological features (including the presence of clay or rock barri

For more information, see section 3.2 in the Australian drinking water guidelines (reference 1d).

Operational protection strategy

Rural activities, animal management and gardens

31 The use of agricultural chemicals that are toxic and persistent in the environment should be minimised or avoided where practical. The Department of Health's Environmental health branch (reference 4) can advise on the use of pesticides in the vicinity of drinking water sources.

32 Agricultural activities should be operated with native vegetation buffers to water sources. Stock should not have access to surface waters, wells, or bores that are used for domestic water supplies. For more information on buffers see our WQPN 6 Vegetated buffers to sensitive water resources (reference 6b).

33 Feral animals, such as cats, dogs, camels, goats, pigs or escaped stock may pose a contamination risk to waters from their droppings and soil erosion. These animals should be captured or culled. For more detailed advice, see our WQPN 96 Pest animal management in public drinking water source areas (reference 6b).

Rubbish disposal

34 In remote areas, where local government waste collection services are often not available, household and non-hazardous industrial wastes generated on-site should be disposed of by land-filling within low permeability soils (such as clay) where practical or otherwise within a resilient synthetic liner (reference 6b). Landfills should be situated downstream or as remote as practical from any drinking water source.

35 Hazardous wastes, including farm chemicals, pesticides, solvents and waste oils, should be separated from general rubbish, placed in sealed drng.

43 Environmental management guidelines or codes of practice that may assist in reducing the risk of water contamination should be used (references 3, 4, 5, 6 and 9

52 Strategies should be developed to manage any incidents within the area defined as requiring water source protection.

53 Contact details for people or agencies expected to respond to significant emergencies should be determined and publicised within the local community.

54 Operators should liaise with neighbours and relevant government agencies and erect signs to ensure they are made aware of the water resource protection area, its value and vulnerability to contamination.

55 A contingency plan including back-up water

drinking water source protection plan where the issues and/or water source are particularly significant.

Operator awareness and training

62 Operators of water supply schemes should be adequately trained and equipped to ensure that the system continuously delivers an adequate, safe and aesthetically acceptable water supply. Training may be obtained from established water service providers, technical and further education colleges or water equipment suppliers.

Community involvement and awareness

63 The community should be encouraged to effectively support the source protection strategy by:

a Raising local awareness of the need for, and benefits of water source protection

b Erecting and maintain clearly visible signs depicting key areas subject to protection (such as wellheads, reservoirs and where necessary and practical, water bodies in the catchment), using wording or symbols alerting people to aspects of the source protection strategy

c

66 An annual report should be prepared that defines system and operator performance. Any deficiencies should be determined and a program proposed to remedy these deficiencies. This information should be shared and discussed with water users.

Review and enhancement

67 The annual report on the water supply system should be assessed independently of the operator and any need for improvements and their priority defined. The system

These areas are each managed with a different strategy to provide for effective water resource protection. P1, P2 and P3 areas are assigned in drinking water source

For additional explanatory information on PDWSA, see this department’s water quality protection note 25 Land use compatibility in public drinking water source areas and note 36 Protecting of public drinking water source areas.

Buffers to water supply sources

Vegetation buffers should separate compatible land use operation areas from the full supply level of reservoirs, their primary feeder streams and production bores used as a source of drinking water. Advice is provided on buffer form and dimensions in our water quality protection note 6 Vegetated buffers to sensitive water resources.

Clearing control catchments

Special controls on vegetation clearing for salinity management purposes are provided under part IIA of the Country Areas Water Supply Act 1947 (WA). These controls apply in the Wellington Dam, Harris River Dam, Mundaring Weir and Denmark River catchment areas and the Kent River and Warren River water reserves.

Details on clearing controls may be obtained from our local regional office, see <www.water.wa.gov.au>, select Contact us.

Established activities in PDWSA

Many land use activities were approved and established before publication of a source protection plan or strategy. We encourage the operators of all land use activities to progressively improve their environmental management facilities and practices so the risk to water resources is minimised (factori

Important underground ecological functions that may be at risk include stygofauna and microorganisms in aquifers (within sand, gravel and karst soils).

4 Waterway ecological and social values

a Maintenance of waterways of high conservation significance described in the WA Environmental Protection Authority's guidance statement 33 Environmental guidance for planning and development (section B5.2.2). This statement is available online at <www.epa.wa.gov.au> select EIA > guidance statements.

b Waterways managed by the Department of Water under the Waterways Conservation Act 1976 (WA). These including the Avon River, Peel-Harvey Inlet, Leschenault Inlet, Wilson Inlet and Albany waterways.

c Waterways managed under Section 9 of the Water Agencies (Powers) Act 1984 (WA). For online advice, see <www.water.wa.gov.au> select managing our water > managing our rivers and estuaries.

d Waterways managed by the Swan River Trust under the Swan and Canning Rivers Management Act 2006 (WA). For online advice, refer to <www.swanrivertrust.wa.gov.au>.

e Social values in natural waterways include their aesthetic appeal, use of watercraft, fishing, tourism, swimming and other aquatic activities.

Engineered drains and constructed water features are normally not assigned ecological values because their function and operational factors override these water values.

5 Wetland ecology

a Ramsar wetlands, described online at <www.ramsar.org>.

b Wetlands defined by the Australian government in the Directory of important wetlands in Australia, available online at <www.environment.gov.au> select water > water topics > wetlands.

c Wetlands of high conservation significance described in the Environmental Protection Authority (WA) guidance statement 33 Environmental guidance for planning and development (section B4.2.2). This is available online at wwwu/P <</MCu25 dl9

wetlands is provided on the same site at water > wetlands > data; or by phoning DEC's nature conservation division on 08 9334 0333.

Wetlands that are highly disturbed by rural land use, or have been landscaped to provide a social amenity or drainage control function in urban settings, may not have ecological conservation values unless they are being actively managed to restore these values.

Note interpretation

Many aquifers, waterways and wetlands in Western Australia require detailed scientific evaluation and their values remain unclassified. Unless proven otherwise, any natural waters that are slightly disturbed by human activity are considered to have sensitive values.

Community support for water values, the setting of practical management objectives, providing sustainable protection strategies and effective implementation are vital to protecting or restoring our water resources for current needs and those of future generations.

This note provides a general guide on issues of environmental concern, and offers solutions based on professional judgement and precedent. Recommendations made in this note do not override any statutory obligation or government policy statement. Alternative practical environmental solutions suited to local conditions may be considered.

This note shall not be used as this department's policy position on a specific matter, unless confirmed in writing. The note may be amended as needed, when new data is available. Regulatory agencies should not use recommendations made in this note in place of site-specific conditions based on a project's environmental risks. Any regulatory conditions should consider the values of the surrounding environment, the safeguards in place and take a precautionary approach.

Where a conflict arises between recommendations made in this note and any proposed activity that may affect a sensitive water resource, this note may be used to assist negotiations with stakeholders. The negotiated outcome should not result in a greater risk to water quality than would apply if our recommended protection measures were used.

This note will be updated as new information is received or industry/activity standards change. The currently approved version is available online at <www.water.wa.gov.au> select publications > find a publication > series browse > water quality protection notes.

Appendix B: Relevant statutory controls include:

What is regulated?	Western Australian statutes	Regulatory agency
Development approval	Planning and Development Act 2005	Local Government Authority Department of Planning <www.planning.wa.gov.au>
Impact on the values and ecology of the environment, including waters; licensed	Environmental Protection Act 1986,Part IV Environmental Impact Assessment	Environmental Protection Authority <www.epa.wa.gov.au>

What is regulated?	Western Australian statutes	Regulatory agency
landfills		Department of Environment and Conservation <www.dec.wa.gov.au>
Supply of potable water supplies to communities of more than 250 people	Water Services Licensing	

- WQPN

To comment on this note or seek any clarification, please contact our water source protection branch (details below), citing the note topic and version.

Manager, Water Source Protection
Department of Water
168 St Georges Terrace
Perth Western Australia 6000

PO Box K822
Perth Western Australia 6842

Telephone +61 8 6364 7600
Facsimile +61 8 6364 7601
Email waterquality@water.wa.gov.au
National relay service 133 677

To locate our regional offices online, see www.water.wa.gov.au, then select Contact us.

This publication is available at our website <www.water.wa.gov.au>. For those with special needs it can be made available in alternative formats such as audio, large print, or Braille.

June 11-PR-(14324)