Minutes

Proposal 2 – Clarifying circumstances in which a hybrid facility comprising a load and electric storage resource (ESR) component must register as a Scheduled Facility:

The Chair noted the responses, questions and clarifications as per Slide 5 and noted that the WEM Rules have guidance on how ESR is treated in other circumstances, with AEMO having discretion about registration facility type.

The Chair asked whether the rules should provide flexibility if the load is larger than the ESR component.

Mr Butler clarified AEMO's submission related only to facilities over 10MW that are categorised as scheduled, not to smaller hybrid facilities.

Mr Butler stated that AEMO is unsure why hybrid facilities should be treated differently to other facilities.

The Chair stated that the proposal is to allow a participant the choice whether to register as a DSP or Scheduled Facility for the purpose of receiving capacity credits. If a facility is a scheduled facility, the component that can have capacity credits is the ESR component, not the load.

Mr Price responded that a facility can manage its IRCR exposure in addition to receiving capacity credits for the amount it can inject net of its load.

The Chair noted there is a specific prohibition against doing that using ESR which has capacity credits.

The Chair noted that a load can have a diesel generator to reduce its withdrawal and get capacity credits for that as a DSP, and that the same should apply for a load and ESR.

Mr Price responded that a facility cannot currently have over 10MW with a diesel generator without being registered as an intermittent load.

Ms Bedola said there are two issues that need to be understood:

- If a load can reduce on its own, with the ESR providing a separate response, why can't both components get capacity credits (with appropriate submetering)?
- Regarding the obligations of a scheduled facility that is comprised of a load and ESR – does the ESR need to smooth the load to meet the requirements of a scheduled facility?

The Chair said that those questions are answered by the fact that a facility currently cannot be registered as both a DSP and a Scheduled Facility (or any other facility type).

Item	Subject

Proposal 3 – Use of Western Power sub-metering in the STEM and RTM by hybrid facilities:

The Chair noted the responses, questions and clarifications as per Slide 6. She added that this would be optional, and that other low-cost options won't be compliant with national legislation if the meters are used for settlement purposes.

The Chair asked for feedback on the complexities that may arise from this proposal.

Ms Kogon noted the following complexities:

- physical access to the customer side of a meter and the condition of customer owned equipment were both issues to consider.
- Western Power will likely need to define a minimum safety standard for customer equipment, which would need to be upgraded at the customer's expense if it is not up to standard.
- Western Power needs to raise awareness about minimum safety standards and enforce those requirements, increasing liability and risks which could add to Western Power's costs.
- Western Power's existing processes and systems will need to be refreshed to accommodate these changes.

The Chair cited independent connection providers in the United Kingdom to demonstrate similar arrangements had been implemented elsewhere in the world.

The Chair asked Ms Kogon whether the complexities could be solved by contractual arrangements.

Ms Kogon said that was a legal question regarding Western Power's compliance with state and national legislation.

Mr Schubert said that a cooperative approach between Western Power and a network customer could address most of Ms Kogon's concerns and would be simpler than a WEM Rules based approach.

Mr Price noted the need for some limitations – if this was offered to any hybrid facility, there would be some consequent management of matters such as loss factors, definition of a connection point, limitations on multiple market participants owning facilities behind a single connection point, management of outages and constraint equations. AEMO is supportive of enabling the most flexibility for each component, and there is an appetite for this, but that analysis is required to support this.

Ms Kogon agreed a cooperative approach was appropriate but noted that, to address the risk, the redefined role and responsibilities of Western Power and market participants/customers needed to be reflected somewhere, whether that is in a contract, agreement, rules or regulations.

The Chair noted that there will need to be calculations in the rules to manage the submetering arrangements, as those that exist for the City of Kambalda, and that this is expected to only be applicable for hybrid facilities with a load.

Mr Price noted there is an appetite for non-load hybrids wanting to split their facility behind an existing connection point to participate in multiple markets.

The Chair stated that the cost and time of implementing the proposal needs to be understood, as well as the actual demand for this type of arrangement.

The Chair asked for other views.

Mr Huxtable noted that the complexity will just be part of the cost of doing business to enter into these arrangements and could be sorted out contractually.

Mr Alexander asked for an example of the risk in laypersons terms.

Item	Subject
	Ms

Item	Subject
	as the new flexible capacity product, may change the

Item	Subject

The Chair summarised AEMO's view that procedures are the right place for telemetry requirements and that issues that have been raised are already being addressed.

Proposal 12 – No changes to DSR ability to register as Interruptible Load and DSP and receive capacity credits at same time as providing Contingency Reserve Raise (but rotation methodology to be developed):

The Chair summarised the responses and questions as per Slide 14 and noted:

There has previously been discussion about the rotation of DSPs and why Interruptible Loads are not being dispatched to the same extent;

Interruptible Loads should still be able to provide ESS services;

in the past there was a methodology for the rotation of DSPs;

she disagrees with AEMO's view that the rotation method should be in procedures as it could have financial impact on participants.

The Chair invited views from the rest of the group.

Mr Ross queried whether flexibility in choosing the 'best' load to dispatch each time would be lost by implementing a rotation method.

The Chair responded that without a rotation method there are issues with one party having to make a decision about who to dispatch each time and on what basis. She noted that some DSPs that are not Interruptible Loads have expressed views that they are repeatedly dispatched as they are large and have proven their capability. Interruptible Loads shouldn't be dispatched if they are in merit to provide contingency reserve raise, but as more DSPs enter the market there needs to be assurance that dispatch will be equitable.

Mr Schubert suggested a lack of activation payment might ultimately be responsible for the lack of participation.

The Chair stated that a loss of production is the primary concern for participants.

6b **Dynamic Baseline proposal**

Mr Carlson presented Slide 17, noting that:

the design elements presented are drawn from the United States National Action Plan on Demand Response; and

not all exclusion rules presented would be used in the WEM.

Mr Carlson presented slide 18. He noted that the calculation should be simple and understandable – there are more complex and expensive methods but the accuracy benefits are marginal. He noted that:

Demand response events happen when demand is the highest, and as such adjustments are usually needed to the observed consumption in the previous days to establish an accurate baseline;

The extent to which an adjustment is needed will depend on the methodology that is used to establish the baseline – one that already excludes low demand days (e.g. a 5 in 10 methodology using the highest demand days) would require less adjustment; and

The adjustment window cannot go back a lot further than the call to respond otherwise the risk of gaming arises.

Mr Carlson presented Slide 20. He noted that:

many demand response providers would be operating across the NEM and WEM; and

predicting the underlying load depends on a baseline methodology that is accurate, lacks bias and is predictable.

Item	Subject

Item	Subject

The Chair asked whether an 8 of 10 baseline should be used, excluding the lowest and highest days.

Mr Schubert asked how the baseline calculation would allow for temperature dependent loads with different measurements on different days.

Mr Ditric responded that day-of adjustments and scalar would be used to capture that.

Mr Ditric presented slide 23. He noted that

consumption two hours prior to the dispatch instruction is used to adjust the baseline up or down as required; and

an adjusted baseline is only calculated if a dispatch instruction is given.

The Chair invited views on the proposed approach but there were none.

Mr Ditric presented slide 24. He noted that this proposal is the same as reserve capacity testing for DSPs, but that it is from the adjusted baseline level.

The Chair invited final comments on the proposed baseline methodology.

Mr Cornish asked (with regard to slide 28) how the bias/accuracy threshold would be calculated for RCM purposes and whether a DSP's portfolio would be found not available if outside of that.

Mr Ditric noted that a bias threshold is not proposed in the WEM, as when a DSP is accredited they may not have all their loads associated at that point in time.

Mr Butler asked why there would be an ex-post review if there were changes to associated meters.

Mr Ditric said if a meter had moved away and that was not reflected in the initial settlement run, it might be necessary to re-calculate the baseline against which the DSP was dispatched.

The Chair noted that while the baseline has beenn