Item	Subject
1	**Welcome** The Chair opened the meeting with an Acknowledgement of Country.
2	**Meeting Apologies/Attendance** Noted as per the above.
3	**Competition Law Statement** The Chair asked attendees to note the Competition Law Statement provided with the meeting papers and invited attendees to raise any competition law concerns that might arise.
4	**Minutes** The Chair noted the minutes for the previous DSRRWG meeting of 29 November 2023 were approved and published out of session.
5	**Action Items** <u>Item 2 – Western Power to provide an overview of the extent to which the Eastern Goldfields Load Permissive Scheme (ELPS) has been successful:</u> The Chair invited Ms Kogon to address this with reference to the material Western Power had previously provided from this Item, which EPWA had circulated to working group members. Ms Kogon noted the ELPS overview and video were circulated to the working group. Mr Schubert noted that, while information had been provided on how this scheme operates, no information had been provided on how successful it was. Ms Kogon stated that in Western Power's view, the ELPS had benefited customers by redistributing available capacity and therefore allowing customers to connect when they might not otherwise have been able to. Mr Trumble disagreed with the conclusion that it had been successful. This Action was closed. <u>Item 3 – Western Power to confirm whether there is a size threshold above which new loads are required to contribute to network augmentation and, if so, what it is and whether it distinguishes between transmission and distribution:</u> The Chair introduced the Item and referred to previous email advice sent to EPWA by Western Power addressing it, which had not yet been discussed by the working group. Ms Kogon stated that there is not a threshold per se, but Western Power has an obligation to

Item	Subject

The Chair stated that the purpose of the clause was to enable the regulator to monitor for gaming of the baseline and that the wording would be changed to clarify that the behaviour is “solely for this purpose”.

Mr Carlson stated that:

> There are legitimate reasons a load would vary its demand, such as a large refrigeration load turning up to be able to sustain an upcoming curtailment.
>
> Intent is difficult to prove, and a regulator would want to see an explanation of why consumption was increased. If a participant can prove that it turned up for operational needs, that would normally be satisfactory to regulators.
>
> The ERA has implemented guidelines for trading conduct, so one option would be to expand those guidelines

Item	Subject

Action: EPWA to redraft this clause to remove the concept of intent, look at the use of inappropriate/anomoulous behaviour and make the wording consistent with the rest of the rules as far as is practicable

Proposed clause 2.27B.9 -

Item	Subject

The Chair noted that every effort should be made to ensure that capacity comes through the RCM, and that the question at hand is what can be done in the RCM to make sure it is attractive for demand side response to participate in.

Mr Trumble noted that it was unclear what NCESS costs were.

Item	Subject

Item	Subject

7 **Hybrid Facility Sub-metering**

Mr Ditric introduced this item and asked the working group what the objective of hybrid submetering was - to allow two facilities to operate separately, or to have a single facility with multiple meters but all settled separately.

Mr Huxtable suggested that the intent is to operate the components as separate facilities.

The Chair said that this approach is extremely complex for more than one sub-metered component.

Ms Bedola noted that initially it may be separating the load from other components, so that the load can be subtracted from the total at the NMI, and that this would be the lowest cost option. Down the line, it may become desirable to have multiple individual facilities behind the same connection. The nature of components behind the connection point would drive which option is more desirable.

Mr Huxtable said that when the battery in a hybrid facility discharges and the load increases at the same time, the meter at the connection point will read as though a facility is not delivering what is expected.

The Chair confirmed that this would involve a Scheduled or a Semi-Scheduled facility behind the main meter that is separately metered for settlement purposes.

Mr Huxtable said that this was his original intent, but there is added confusion if the load is a DSP.

The Chair confirmed that allowing this involved a lot of complexity.

Mr Huxtable said that if allowing just one component to register as a separate facility was easier, then having this would be acceptable.

Mr Price noted that it depends on the use case, and the feedback AEMO has had is as per Mr Huxtable's comments - that participants want to recognize the different capabilities of components behind the meter to perform different functions. He questioned whether this needed to be done through submetering, noting that in the NEM separate components behind the connection point can be dispatched separately, but are settled at a common metering point for energy. He stated that there could also be completely independent facilities with separate meters. However, this option raises questions about where the notional connection point is, and who is responsible for loss factors and network outages.

The Chair said that the goal is to [illegible] physical connections in the network to separate that facilities and noted that EPWA is trying to avoid the high cost of connecting facilities in such